

*EnergyPlus*SPARK*DOE-2*BLAST*EnergyPlus*VisualSPARK*DOE-2*BLAST*GenOpt*EnergyPlus*
*EnergyPlus*VisualSPARK*DOE-2*BLAST*GenOpt*EnergyPlus*VisualSPARK*DOE-2*BLAST*GenOpt*

BUILDING ENERGY SIMULATION ★ USER NEWS

*EnergyPlus*SPARK*DOE-2*BLAST*EnergyPlus*VisualSPARK*DOE-2*BLAST*GenOpt*EnergyPlus*
*EnergyPlus*VisualSPARK*DOE-2*BLAST*GenOpt* EnergyPlus *VisualSPARK*DOE-2*BLAST*GenOpt*

Highlights

- 2 ... **EnergyPlus** New Features in Release 1.2.3
- 3 ... **EnergyPlus** Interim Build Released December 14, 2005
- 4 ... Ask an **EnergyPlus** Expert
 - Scripts, Batch Files – COMIS and Nodes – Bypass –*
 - Attached Shading Surface – Internal Gain from Lights –*
 - Outside Air Nodes – Reports, Maximum Heating Rate Values –*
 - Control Node Setup*
- 9 ... **EnergyPlus** New Weather Files (Egypt, China, Kuwait)
- 9 ... 2006 **EnergyPlus** Training Schedule
- 11 ... Spotlight on **SPARK** – FAQ Part 2 of 5
- 13 ... **DOE-2** "QuickQuestion" on External Shading Devices
- 14 ... California Climate Zones on Google Earth™
- 15 ... IBPSA-USA: SimBuild 2006 Conference – Free Membership!
- 15 ... Educational Programs from Southern California Edison
- 16 ... Educational Programs from Pacific Gas & Electric
- 16 ... New Report from FSEC: "*Evaluating Green Roof Energy Performance*" and the Buildings Research Post Newsletter
- 17 ... **VisualDOE** and LEED Training for 2006

Software

- 17 ... **BLAST** News
- 13 ... **DOE-2.1E**
- 10 ... **EnergyPlus 1.2.3**
- 12 ... **GenOpt**
- 14 ... Free Building Energy Software from LBNL

Departments

- 10 ... Free Weather Data on Demand
- 15 ... Building Energy Software Tools Directory (DOE)
- 15 ... Meetings – Conferences – Symposia (Section 2, p. 18)
- 17 ... 2005 Buildings Energy Data Book – *FREE!*
- 17 ... ASHRAE's "*HVAC Simplified*"

The Buzz

The newsletter features of [Ask an EnergyPlus Expert](#) and [DOE-2 Modeling Tips](#) have been compiled for 2005. Click on the active links above or go to our publications page at <http://SimulationResearch.lbl.gov>



EnergyPlus Training: Workshops for both beginning and advanced users are being held in selected cities. The tentative schedule is as follows: either Portland or Seattle in May, and in Cambridge, Mass, on August 1. For details, go to www.gard.com/training.htm



If you want to be listed as an EnergyPlus or DOE-2 consultant in this newsletter and on the Building Simulation web site, email klleington@lbl.gov.

Disclaimer: The Building Energy Simulation User News was prepared as an account of work sponsored by the United States Government (USG). While this document is believed to contain correct information, neither the USG nor any agency thereof, nor the Regents of the University of California (RUC), nor any of their employees, makes any warranty, express or implied, or assumes any legal responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any

PUB-439

specific commercial product, process or service by its trade name, trademark, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the USG or any agency thereof, or the RUC. The views and opinions of authors expressed herein do not necessarily state or reflect those of the USG or any agency thereof or of the Regents of the University of California

EnergyPlus - New Features in Release 1.2.3

Datasets

- Updated all design conditions to match new 2005 ASHRAE Fundamentals data in the weather files and associated design day data
- Extensive set of new example summary report templates for:
 - Space Gains/Envelope/Daylight/Comfort
 - Peak Demand and Consumption
 - Unglazed Transpired Solar Collector
 - HVAC/Electrical Systems/Loops/Components
 - Outdoor Conditions

Input

- Example input files for all new features (more than 200 example files available)
- All example input files have been updated and new documentation of features added
- New weather data for 100 international weather locations including India, Portugal, Brazil, China, Ethiopia, Ghana, Kenya, and Nepal in the EnergyPlus/ESP-r weather format (975 locations available worldwide)
- Revised design days to accommodate "enthalpy" and "humidity ratio" as potential humidity indicating types based on 2005 ASHRAE Fundamentals

Geometry/Windows/Walls/Shading

- User-definable radiation view factors

Zone Model

- User-definable room air temperature distribution model (at this time, for research only)

Electrical Power

- Demand limiting controls

HVAC

- Simple Water to Water GSHP
- Packaged Terminal Heat Pump
- Return air bypass
- Restructured plant loop modeling to support branch pumps and future headered pumps and extensions of controls simulation
- Branch supply pumps for supply side equipment such as chillers, boilers, heat pumps, and water heaters
- Simple ice storage tank
- Heat Pump Water Heater
- Desuperheater Water Heating Coil
- Steam loop, steam coil, steam boiler

On-Site Energy Supply

- Solid Oxide Fuel Cells (research only--for more information on this model contact EnergyPlus-Support@gard.com)

To EnergyPlus Documentation

<http://www.eere.energy.gov/buildings/energyplus/documentation.html>

EnergyPlus - New Features in Release 1.2.3

Continued

Output

- DXF:Wireframe
- New report variables including power and breakout of separate object-level variables for all internal gains objects.
- New report variables to monitor zone temperature when heating and cooling setpoints are not met and when they are not met during occupancy, when zone temperatures oscillate due to poor simulation, and when zone conditions are outside the ASHRAE Standard 55-2004 comfort region.
- Output reporting enhancements including optional unit conversion for J into kWh, MJ or GJ in tabular output; new schedule support for TimeBins report; and table of contents for HTML tabular output files.

Utilities

- New features in EP-Launch including new quick open panel for opening output files, composite error file for group simulations, and integration with the Transition utility to automatically update files to the latest version.
- Many IDF Editor improvements including resizable window regions, opening DDY files, and pull-down list of report variable names from RDD output file.
- New unit conversion utility produces output in user-definable units
- Many new HVAC Diagram capabilities including draws "dangling" pieces that fit together that were not drawn as part of loop, draws lines to represent the loop coming back to the start, long names now wrap to two lines within boxes, and faintly drawn lines connect items that appear in multiple loops such as coils.

Documentation and Guides

- Input/Output Reference and Engineering Reference have been updated and extended for all new features and updates, bringing total documentation to more than 2500 pages.

EnergyPlus Version 1.2.3 ♦ Interim Build (#31) ♦ Released December 14, 2005

A new version of EnergyPlus (1.2.3 build 31) was released for both the Windows and Linux operating systems. Download v 1.2.3 from <http://www.energyplus.gov>. Why a new version just two months after the last one? There are a few cool new features that we wanted to get out to you and some bug fixes that we didn't want to leave till Version 1.3 (scheduled for release in April 2006).

What's New in EnergyPlus Version 1.2.3 Build 31 ???

- UFAD (Underfloor Air Distribution) for interior zones is now available as an alternative RoomAir option. (Exterior zones UFAD are planned for April 2006.)
- Detailed coil models can now be auto-sized.
- Ventilation improved with the addition of maximum indoor temperature, minimum/maximum outdoor temperatures, and maximum wind speed to help control natural ventilation.

Ask an EnergyPlus Expert

SCRIPTS, BATCH FILES

I'm trying to find a way to automatically do lots of runs in EnergyPlus. I need to do a single parametric sensitivity analysis and, therefore, need to vary one parameter at a time, save the file, run it and check the results. I had a look at the macros but I'm not sure if they are appropriate as it seems to me that each file needs to be specified anyway and saves should be done manually. I thought I could use the `##def` to define all my variables in some files and then use the `##if` and/or `##include` to substitute each one in the "basic" .idf file but I couldn't find a way to save the file each time before running. So now I have a collection of input files - each of them with only one different variable! I opened a macro example and saw that a macro command should be included inside the .idf file so that it calls the corresponding .imf file. However, I need to use the same .idf file many times, changing one of the variables each time. By doing this I would need to save the files manually if I decide to use a macro command. So, the only way to do a parametric sensitivity analysis is to write a script in order to manipulate the .idf text files – right?

Answer

It is not necessary to save the files manually. The imf macro system is designed to do exactly what you want. You can run thousands of parametric runs all from a single imf input file. Remember that the epimdf output file is saved for future reference, and it shows the final resulting input for EnergyPlus after all macro processing is completed. The key is to use an output file naming scheme that prevents the outputs from overwriting each other.

One option for doing this is to use the Group capability in EP-Launch (see the Getting Started document). Make your master input file a *.imf file (which can then have `##includes` of other idf or imf files). With the EP-Launch group simulations, there is an optional counter for running the same file multiple times. A file called "COUNTER.INC" is written prior to each simulation which sets a macro variable called "Counter." The imf input file can then have `##IF` blocks that set other variables based on the current value of counter[].

Another option is to write your own batch files which call `runepplus.bat`. Again, the approach to use is to have the batch file write a short file such as "parameters.inc" (can be any extension you like) with `##set1` statements in it to set the desired parameters for a single run. Then in the master imf file `##include` parameters.inc at the top of the file. Then the rest of the file can have `##IF` block that are controlled by the variables which were set in parameters.inc.

We know this is rather confusing at first, but it turns out to be quite simple and powerful once you get past the initial learning curve.

From the March-to-August 2003 User News ...

Question

I have to run quite a lot of (large and time consuming) simulations. Is it possible to use a batch file to queue the IDF files?

Answer

Yes, you can run EnergyPlus with batch files. There is a batch file included, called "RunEplus.bat" in the main EnergyPlus folder. Just write another batch file which calls RunEplus.bat multiple times. (Note, use the "call" command to execute RunEplus so that the main batch file will wait until it is complete). For more information about RunEplus.bat, see the Getting Started document, pp. 14-18.

Find EnergyPlus Documentation At

<http://www.eere.energy.gov/buildings/energyplus/documentation.html>

Ask an EnergyPlus Expert

COMIS AND NODES

I have a one zone model and use COMIS for natural ventilation. I need to determine mass flow through two openings on opposite sides of the zone and I need to define two external nodes at each of the two windows through which the air flows. But can I define a node in the middle of the zone for use only in COMIS? I can't find it in the manual? Only thing I can find is the defining of nodes for all types of mechanical ventilation. Or do i use 'Air mass flow from fromzone to tozone' for this?

Answer

The nodes used in the HVAC system inputs are not the same nodes used in the COMIS simulation. "Air Flow from FromZone to ToZone through COMIS Link" (and the reverse "Air Flow from ToZone to FromZone through COMIS Link") are what you want to report. Note that large openings can have bidirectional flow (for example, air can flow out the top of a large open window and flow in at the bottom) so you need to report both directions.

The Air Mass Flow FromZone to ToZone report variable describes the air flow across a surface (from an external node to a zone node).

The external node you describe is required (or not) based on the input for the COMIS Simulation object.

From the IO Reference manual:

COMIS Simulation object

Field: Wind Pressure Coefficients

Determines whether the wind pressure coefficients are input or calculated. The choices are INPUT or SURFACE-AVERAGE CALCULATION.

- If INPUT, you must enter a COMIS CP Array object, one or more COMIS External Node objects and one or more COMIS CP Values objects.
- The second choice, SURFACE-AVERAGE CALCULATION, should only be used for rectangular buildings. In this case surface-average wind pressure coefficients vs. wind direction are calculated by the program for the four vertical facades and the roof based on your entries for "Building Type," "Azimuth Angle of Long Axis of Building," and "Ratio of Building Width Along Short Axis to Width Along Long Axis" (see description of the following three fields). With this choice you do not have to enter any of the following objects: COMIS CP Array, COMIS External Node and COMIS CP Values. The calculated wind pressure coefficients are shown in the eplusout.cif file (see the example COMIS input file, next page).

Continued on the next page

Ask an EnergyPlus Expert

COMIS AND NODES (CONTINUED)

Use this method when the wind pressure coefficients field is set to INPUT:

```
COMIS EXTERNAL NODE,  
  SFacade,          !- Name  
  1.0;              !- Outside Pollutant Concentration Factor  
{dimensionless}
```

```
COMIS SURFACE DATA,  
  Surface_1,        !- Name of Associated EnergyPlus Surface  
  CR-1,             !- Name of Air Flow Crack or Opening Type  
  SFacade,          !- External Node Name  
  1;                !- Crack Actual Value or Window Open Factor for  
Ventilation {dimensionless}
```

Use this method when the wind pressure coefficients field is set to SURFACE-AVERAGE CALCULATION:

```
COMIS SURFACE DATA,  
  Surface_1,        !- Name of Associated EnergyPlus Surface  
  CR-1,             !- Name of Air Flow Crack or Opening Type  
  ,                 !- External Node Name  
  1;                !- Crack Actual Value or Window Open Factor for  
Ventilation {dimensionless}
```

For COMIS inputs you do not specify an internal node in a zone, use the zone name in the COMIS Zone Data objects and a surface name in the COMIS Surface Data object.

So try outputting the Air Mass Flow FromZone to ToZone and Air Mass Flow ToZone to FromZone report variables and see what happens.

BYPASS

I am modeling a huge building and am only simulating only the building side (and not the plant). I understand that I need to use only purchased chilled water supply and purchased hot water supply instead of chiller and boiler, respectively. Now coming to my question. Do I really need to use bypass pipes for each purchased chilled water and purchased hot water.

Answer

Bypass pipes should not be necessary if the pump is intermittent, but it never hurts to have one even if it is never used.

I am puzzled that you say for "each purchased chilled water and purchased hot water". You only need one purchased chilled water and one purchased hot water to supply the entire building. One hot water loop supplying all hot water coils with a single purchased hot water supply object. Likewise for the chilled water side. For an example, see the hot water loop in TermReheat.idf

Ask an EnergyPlus Expert

ATTACHED SHADING SURFACE

I have an attached shading surface with some openings. However, I don't know how to describe these openings geometrically. I've considered using the field "Fraction of Shading Surface That Is Glazed" in shading the surface reflectance object without geometrically describing the openings. Then, to model the openings, I would use a window glass with very high transmittance and very low reflectance. Would this be correct?

Answer

"Fraction of Shading Surface That Is Glazed" in shading surface reflectance only affects the way the shading surface ***reflects*** sunlight, it does not alter the transmittance of the shading surface.

Shading surfaces are opaque, unless the the transmittance schedule (field "TransSchedShadowSurf") has values greater than 0.0. The easiest option is to set the shading surface transmittance schedule to AreaOfHoles divided by TotalAreaOfShade.

INTERNAL GAIN FROM LIGHTS

I need to set the design level of lights in order to calculate internal gain. According to daylighting illuminance, some fraction of the lights are switched on or not. Does EnergyPlus consider that situation while calculating the internal gains of lighting? I know there is a relation between the lighting consumption and daylighting illuminance, but is there also any relation between internal gain of lighting and daylighting?

Answer

Yes. When the power consumption of LIGHTS is reduced by daylighting controls, the internal heat gain is also reduced. The following report variables can be used to verify this: Ltg Power Multiplier from Daylighting, Lights Total Heat Gain, Lights Electric Consumption, Zone Total Internal Total Heat Gain.

OUTSIDE AIR NODES

I am using room AC packaged units with outside air mixers, fans, DX heating and cooling coils and electric heaters. If I use a common outside air node (NOUTSIDE) for all the room AC units and the outside air mixers, I get lots of Warning and Severe messages. If I use a different outside air node for each room unit (e.g., NOUTSIDE1, NOUTSIDE2, etc.), then I get no errors. Why can't I use a common outside air node?

Answer

Each outside air inlet node must be unique. Why? Because the outside controller, or in this case the window AC unit, sets the mass flow rate on the outside air inlet node. Then the mixer component, which is passive, takes the mass flow present on the outside air inlet node and mixes it with the flow from the return air node. HVAC nodes in EnergyPlus are single point inlets or outlets to a piece of equipment.

Ask an EnergyPlus Expert

REPORT -- MAXIMUM HEATING RATE VALUES

I have noticed that maximum heating rate values obtained with Report:Table:Monthly are very different (much larger) than the ones that can be obtained from the report of heating rates in Report Variable. This happens when using Purchased Heating as well as with a Heat Pump System. Am I overlooking something or doing something wrong ?

Answer

Max values in table reports are computed for each timestep. Our guess is that the report variables are being reported hourly, so you are only getting the maximum rate averaged over one hour in that view. Set the REPORT VARIABLE reporting frequency to TIMESTEP (for Zone timestep variables) or DETAILED (for HVAC timestep variables), and the max values should match what is reported in the table report.

CONTROL NODE SETUP

I have a fixed flow system feeding two zones. On the air loop there's a cooling coil and a supply fan followed by a steam humidifier. Then I have two separate reheat coils serving the two zones. In these zones I want to control both the temperature and the humidity.

I have a CONTROLLER:SIMPLE for each of the coils (one cooling, two reheats) and SET POINT MANAGER:SINGLE ZONE REHEAT for the reheats and SET POINT MANAGER:SINGLE ZONE COOLING for the cooling coil.

I'm able to get control of the RH or the temperature in the zones but not both at the same time.

Could my control nodes be the source of the problem?

Answer

Since you have two reheat coils, I assume that they are part of a terminal unit such as SINGLE DUCT:CONST VOLUME:REHEAT or SINGLE DUCT:VAV:REHEAT. These components have the reheat controls built into the terminal unit and do not require a set point manager or a CONTROLLER:SIMPLE object. SET POINT MANAGER:SINGLE ZONE REHEAT is used to control coils in the main branch of an air loop, not in terminal units.

To control dehumidification, the cooling coil requires both a temperature set point manager and a Set Point Manager:Single Zone Max Hum to override when humidity control is required.

If this system is serving two zones, SET POINT MANAGER:SINGLE ZONE COOLING will not work, because it will control the cooling coil for only the single zone to which it is attached. SET POINT MANAGER:WARMEST may be better for this application.

Find EnergyPlus Documentation At

<http://www.eere.energy.gov/buildings/energyplus/documentation.html>

EnergyPlus



NEW WEATHER FILES

We have just published new weather data in EnergyPlus format on our web site:

Egyptian Typical Meteorological Year (ETMY)

A set of 10 typical year weather files for locations throughout Egypt, developed by Joe Huang, Joe Huang and Associates.

Chinese Standard Weather Data (CSWD)

A set of 270 typical year weather files for locations throughout China, developed by Tsinghua University and China Meteorological Bureau.

Kuwait Weather Data from Kuwait Institute for Scientific Research (KISR)

Two weather files for Kuwait based on measured meteorological data for Kuwait International Airport and KISR's coastal weather station.

This brings the total number of weather data locations available on the web site to more than 1100 (some locations have multiple sources of data). More information about data sources is available here: http://www.eere.energy.gov/buildings/energyplus/weatherdata_sources.html

The EnergyPlus Team



All weather data are available at
http://www.eere.energy.gov/buildings/energyplus/cfm/weather_data.cfm.
If you know of other typical weather data that could be shared with EnergyPlus users,
please contact [Dru Crawley](#) or [Linda Lawrie](#) directly.

2006 EnergyPlus Training



May ???

Seattle, Washington or Portland, Oregon

We are currently seeking hosts for a Portland/Seattle workshop in May 2006, or for additional sites if there is sufficient interest. If your organization would like to host an EnergyPlus workshop, please contact EnergyPlus-Training@gard.com. Hosting may cover a range of services, and can be as simple as providing a meeting room for up to 20 participants with laptops. Free registrations may be made available to the host organization.

August 01

Cambridge, Massachusetts (at MIT)

Immediately before the IBPSA-USA SimBuild Conference at MIT
Early registration deadline is June 28, 2006; Registration closes after July 24

<http://www.gard.com/training.htm>

EnergyPlus Version 1.2.3

Download a free copy of the program

<http://www.energyplus.gov/>

Support Tools

Support software is listed on our website (http://SimulationResearch.lbl.gov/EP/ep_tools.html) and in Section 2 of this newsletter.

Weather Data from http://www.eere.energy.gov/buildings/energyplus/cfm/weather_data.cfm

Weather data for more than 800 locations are now available in EnergyPlus weather format. See the write-up on how to [create Meteorom files for EnergyPlus](#).

Ask an EnergyPlus Expert

Questions from EnergyPlus users are answered promptly via email by program developers. To submit questions, join the EnergyPlus User Group at http://groups.yahoo.com/group/EnergyPlus_Support/.

A selection of questions/answers are compiled (yearly) into a downloadable PDF document: Q and A for [2002](#), Q and A for [2003](#), Q and A for [2004](#), Q and A for [2005](#)

Are you an EnergyPlus Consultant ?

If you are engaged in EnergyPlus consulting, and would like to be listed in the *Building Energy Simulation User News* and on our website (<http://SimulationResearch.lbl.gov>), please send details to klellington@lbl.gov.

Join the EnergyPlus User Group

The developers of EnergyPlus have formed a support group to foster discussion and maintain an archive of information for program Users. We invite questions about program usage and suggestions for improvement to the code. Go to http://groups.yahoo.com/group/EnergyPlus_Support/

Testing and Validation <http://www.eere.energy.gov/buildings/energyplus/testing.html>.

EnergyPlus is being developed by University of Illinois and Lawrence Berkeley National Laboratory, with the assistance of DHL Consulting, C. O. Pedersen Associates, Florida Solar Energy Center, GARD Analytics, the National Renewable Energy Laboratory, Oklahoma State University and others. Development of EnergyPlus is supported by the U. S. Department of Energy, Assistant Secretary for Energy Efficiency and Renewable Energy, Office of Building Technologies Program (Program Manager, Dru Crawley).

The Forecast Looks Favorable for ...

(Free!) Weather Data on Demand

Access archived weather data from around the world through this U.S. DOE web interface:

www.eere.energy.gov/buildings/energyplus/cfm/weatherdata/weather_request.cfm

Hourly weather data is continuously collected and stored into a local database, available through this web interface. Most stations have information for dry bulb temperature, wet bulb temperature, wind speed/direction, atmospheric pressure, visibility, cloud conditions, and precipitation type.



Spotlight on SPARK – Part 2 of 5

Frequently Asked Questions about the Simulation Problem Analysis and Research Kernel Software

Download VisualSPARK 2.01 (Free!) from http://gundog.lbl.gov/VS/vs201_eula.html

This is a list of frequently asked questions (FAQ) for VisualSPARK users. If you need help for something that is not covered by the [SPARK Reference Manual](#), the [SPARK Atomic Class API](#), the [SPARK Problem Driver API](#), or this FAQ, please email us.

This FAQ is intended to supplement, not replace, the SPARK documentation. Before emailing us a question, you should first check to see if the topic is covered in the various manuals.

[SPARK Runtime Controls](#)

- [How to perform a simulation with adaptive time stepping?](#)
- [How to specify an "infinite" final time?](#)
- [How to generate reports for all computed steps?](#)

Runtime control parameters for the simulation run are specified in an ASCII file with extension *.run using the so-called preference syntax. The preference syntax relies on set of parenthesis "(")" to identify the various tokens in a tree-like structure. In this section we discuss issues pertaining to the runtime control parameters only, independent of the file format.

[How to perform a simulation with adaptive time stepping?](#)

In order to perform a simulation with adaptive time stepping you should set the key VariableTimeStep to 1 in the *.run file. By default, it is set to 0, which will perform a simulation with constant time step.

```
( ...  
  VariableTimeStep ( 1 () )  
  MinTimeStep      ( 1.0e-6 () )  
  MaxTimeStep      ( 10.0 () )  
  ...  
)
```

When performing a simulation with variable time stepping it is recommended to also set the minimum allowed time step and the maximum allowed time step using the keys MinTimeStep and MaxTimeStep.

Setting the key VariableTimeStep to 1 in the *.run file tells the solver that it should adapt the time step to respond to various time-related requests. For example, the solver will try to synchronize the global time with the user-requested meeting points or the various report and input events. However, the most important application of the adaptive time stepping operation is in conjunction with the new integrator classes that provide automatic integration error control. These new integrator atomic classes adapt the simulation time step so that the estimated integration error in the dynamic variables satisfies the prescribed relative tolerance specified in the global settings section of the preference settings file.

Please visit our website at <http://SimulationResearch.Ibl.gov>

The new integrator atomic classes can be found in the globalclass directory of your VisualSPARK installation. They are named after the template filename `integrator_method.cc`. Since they define the same port interface as the other integrator classes they can be readily used simply by changing the name of the integrator class in the DECLARE statements.

How to specify an "infinite" final time?

When using the '*' meta-character for the FinalTime entry, you essentially tell the SPARK solver to run the simulation until "infinity". However, because of the fixed-length representation of numbers on computers, infinity really means some large number. Therefore, the simulation will run until the value for the global time variable reaches the biggest possible floating point number in double precision. On a 64-bit architecture with an 8-byte representation of a double type this corresponds approximately to 1.7E+308.

```
( ...  
  FinalTime ( * () )  
  ...  
)
```

How to generate reports for all computed steps?

Specifying a ReportCycle of zero essentially forces the simulator to report the solution values at each computed step. However, a negative report cycle value does not make sense.

```
( ...  
  FirstReport ( 0.0 () )  
  ReportCycle ( 0.0 () )  
  ...  
)
```

More Frequently Asked Questions in the next Newsletter !!



GenOpt 2.0
Generic Optimization Program

GenOpt is an optimization program for the minimization of a cost function, such as annual energy use, that is evaluated by an external simulation program. GenOpt can be used with any simulation program -- such as EnergyPlus, SPARK or DOE-2 -- that has text-based input and output. It also offers an interface for adding custom optimization algorithms to its library.

GenOpt processes discrete independent variables, such as different window constructions, either for optimization problems with mixed discrete and continuous independent variables or for doing parametric studies. Some simulation programs, such as EnergyPlus, cannot pre-process the independent variables or post-process values that are computed during the simulation. For such situations, *input function objects* and *output function objects* can be used without having to modify GenOpt source code.

GenOpt 2.0 (with documentation) may be downloaded free of charge from

<http://SimulationResearch.Ibl.gov>

 <h1 style="font-size: 48px; margin: 0;">DOE-2</h1> 
DOE-2.1E (version 121) 1,000-Zone version for Windows from ESTSC; other vendors of DOE-2 based programs are listed on our website: http://SimulationResearch.lbl.gov/ .
Cost is as follows: \$ 300 U.S. Government/Non-Profits/Education \$ 575 U.S. Public, Mexico, Canada \$1129 to \$1268 Other Foreign
DOE-2 Documentation on a CD from ESTSC - Cost US\$100
<i>What is included on the CD?</i> DOE-2 Reference Manual (Part 1) and (Part 2) DOE-2 BDL Summary (2.1E) DOE-2 Engineers Manual (2.1A) DOE-2 Supplement to the Reference Manual (2.1E)
Order Software and ESTSC Documentation
Ed Kidd or Kim Buckner NCI Information Systems, Inc. Energy Science and Technology Software Center (ESTSC) P.O. Box 1020 Oak Ridge, TN 37831 Phone: 865/576-1037 Fax: 865/576-6436 Email: estsc@adonis.osti.gov
Purchase DOE-2 Documentation
DOE-2 Sample Run Book (2.1E) -- The Sample Run book is the only DOE-2 manual not available electronically. It must be purchased separately from NTIS; ordering information may be found at http://SimulationResearch.lbl.gov > DOE-2 > Documentation
Free DOE-2 Documentation (http://simulationresearch.lbl.gov/> DOE-2 > Documentation)
DOE-2 Basics Manual (2.1E) Update Packages: Update Packages are not cumulative; each one contains different information. Download all four packages then print and insert the pages into your existing DOE-2 manuals. Update Package #1: DOE-2.1E Basics, the Supplement and BDL Summary Update Package #2: BDL Summary and Supplement. Update Package #3: Appendix A of the Supplement. Update Package #4: (1000-zone DOE-2.1E) BDL Summary. DOE-2 Modeling Tips (pdf files) for 2005 for 2004 for 2003 for 2002 A compilation of all the "how to" and "DOE-2 Puzzler" articles from the newsletter. Changes and Bug Fixes to DOE-2.1E (txt file) Description of all changes and bug fixes in a text document.

DOE-2 QuickQuestion

Q: In DOE-2, can external shading devices be modeled with a shading coefficient or a transmittance value, or are they always assumed to be opaque?

A: Yes, you may put a SHADING-SCHEDULE on an exterior shade to change its transmissivity as desired.

California Climate Zones on Google Earth™

Outlines of California's 16 Climate Zones have been overlaid on the aerial images of Google Earth. This is useful if you want to examine the boundary areas between two climate zones. The outlines are based on the GIS (Arcview) shapes. Google Earth is a free broadband, 3D application. Go to <http://earth.google.com/> Once you download, install and launch the application, download and open the Climate Zones CA-CZ.kmz 120 kb file.

The free version does not allow labeling on the map, climate zones can be selectively viewed by using the check box along side each layer. We suggest that you uncheck all the climate zones and then select only the one of interest at the time to view.

Free Building Energy Software from Lawrence Berkeley National Laboratory

BDA 3.1 (*Building Design Advisor*) gaia.lbl.gov/BDA
(building decision-making from design through completion)

COMIS www-epb.lbl.gov/comis (multi-zone air flow and contaminant transport model)

EnergyPlus 1.2.3 www.energyplus.gov/
(next-generation whole-building energy analysis program, based on BLAST and DOE-2)

GenOpt® 2.0 SimulationResearch.lbl.gov (generic optimization program)

Optics 5.2 windows.lbl.gov/materials/optics5/
(for analyzing optical properties of glazing systems)

RADIANCE 3.5 radsite.lbl.gov/radiance/ (analysis and visualization of lighting in design)

Desktop Radiance 2.0β radsite.lbl.gov/deskrad/
(integrates the Radiance Synthetic Imaging System with AutoCAD Release 14)

Radiance Control Panel www.squ1.com/site.html
(automates some Radiance tasks once the model has been created)

THERM 5.2 windows.lbl.gov/software/therm/therm.html (models two-dimensional heat-transfer effects in building components where thermal bridges are of concern)

VisualSPARK 2.0 SimulationResearch.lbl.gov
(*Simulation Problem Analysis and Research Kernel*) (connect component models to simulate innovative building envelope and HVAC systems)

WINDOW 5.2 windows.lbl.gov/software/window/window.html
(thermal analysis of window products)

Free Software / Request by Fax from 510.486.4089

RESFEN 3.1 windows.lbl.gov/software/resfen/resfen.html
(choose energy-efficient, cost-effective windows for a given residential application)

Web Based

Home Energy Saver hes.lbl.gov (quickly computes home energy use)

Please visit our website at <http://SimulationResearch.Ibl.gov>

IBPSA-USA -- SimBuild 2006 -- August 2-4, 2006

To be held at the Massachusetts Institute of Technology in Cambridge, MA, USA
For details, access the website: <http://ceae.colorado.edu/ibpsa/SimBuild06/index.html>

IBPSA-USA will hold its second national conference, August 2-4, 2006 on the campus of the Massachusetts Institute of Technology. Technical sessions over two days will feature presentations on a wide range of topics related to the simulation of HVAC equipment, airflow in buildings, energy usage, and the visual and acoustic environment in buildings, as well as demonstrations of simulation software and of hardware and software needed to emulate or measure the performance of buildings. Friday will be a practitioner day, offering case studies, hands-on software demonstrations and other presentations aimed at giving practicing architects and engineers the information they need to be more informed collaborators with simulation experts. The practitioner day will be coordinated with local US Green Building Council chapters and affiliates.

Free Membership for 2006 -- IBPSA-USA

The [IBPSA-USA](#) Board of Directors has voted unanimously to extend our policy of free membership. Those interested in renewing their membership or becoming new members may do so by expressing their desire to be IBPSA-USA members and providing updated contact information (Affiliation, Mailing address, Phone number, Email address)

Establishing membership may be done on-site at any IBPSA-USA meeting or by sending an email to the IBPSA-USA Secretary, Peter Ellis, at peter_ellis@nrel.gov.
[P] 303.384.7443, [F] 303.384.7540

Meetings, Conferences, Symposia and Workshops



2006

April 19-21	National Conference on Building Commissioning	http://www.peci.org/
April 23-27	Light+Building	www.light-building.messefrankfurt.com
May 17-19	International Conference on Air Conditioning & Ventilation	www.acv2006.cz
May 21-24	5th International Conference HVAC+R Technologies	www.ttmd.org.tr
May 31- June 2	International Conference on Thermal Energy Storage	www.stockton.edu/ecostock

Building Energy Software Tools Directory

This directory provides information on over 300 building software tools for evaluating energy efficiency, renewable energy, and sustainability in buildings. The energy tools listed in this directory include databases, spreadsheets, component and systems analyses, and whole-building energy performance simulation programs. Know of a tool (yours?) that isn't in the directory? Send email to Dru Crawley at Drury.Crawley@ee.doe.gov.

Visit http://www.eere.energy.gov/buildings/tools_directory/about.cfm



Pacific Gas and Electric Company
WE DELIVER ENERGY.™

April 2006 Educational Programs

For a complete listing of classes go to www.pge.com/pec

ARCHITECTURE

Apr 4	Cool Roofing - Materials, Benefits, and Title 24 Requirements
Apr 18	2005 Title 24 Nonresidential Building Envelope Requirements
Apr 26	What Factors Shape A Successful Daylighting System?

H V A C

Apr 6	Energy-Efficient HVAC Design and Control for High Density Data Centers
-------	--

LIGHTING

Apr 20	A Light Affair IV (Evening Lecture)
Apr 26	What Factors Shape A Successful Daylighting System?

RENEWABLES

Apr 5	Understanding Financial Analysis Methods for Photovoltaic (PV) Systems
Apr 25	Combined Heat and Power Applications for Commercial Buildings

TITLE 24 (CALIFORNIA ENERGY CODE)

Apr 4	Cool Roofing - Materials, Benefits, and Title 24 Requirements
Apr 18	2005 Title 24 Nonresidential Building Envelope Requirements

From the Florida Solar Energy Center (FSEC)

Buildings Research Post Newsletter (Winter 2006)



Newsletter: <http://www.fsec.ucf.edu/bldg/resources/newsletter/winter2006/index.htm>

Evaluating Green Roof Energy Performance

by


*Jeff Sonne, Senior Research Engineer
Buildings Research Division
Florida Solar Energy Center
Cocoa FL*

Abstract

Summertime data indicate significantly lower peak roof surface temperatures and higher nighttime surface temperatures for the green roof. The maximum average day temperature seen for the conventional roof surface was 130°F (54°C) while the maximum average day green roof surface temperature was 91°F (33°C), or 39°F (22°C) lower than the conventional roof.

Link to Report:

http://www.fsec.ucf.edu/bldg/resources/newsletter/winter2006/ASHRAE_JeffSonne.pdf



- * **Free!** The 2005 Buildings Energy Data Book includes statistics on residential and commercial building energy consumption. Data tables contain statistics related to construction, building technologies, energy consumption, and building characteristics. Download book from: <http://buildingsdatabook.eere.energy.gov/>
- * **Not Free!** ASHRAE's "HVAC Simplified" Explains fundamental HVAC concepts and simple design tools used to create building systems. Cost is \$79 (\$59, ASHRAE members). To order, go to [http:// www.ashrae.org/](http://www.ashrae.org/)

BLASTnews

www.bso.uiuc.edu

Building Systems Laboratory
University of Illinois, 30 Mechanical Engineering Building,
1206 West Green Street, Urbana, IL 61801
Tel: (217) 333-3977 - Fax: (217) 244-6534
support@blast.bso.uiuc.edu

The Building Loads Analysis and System Thermodynamics (BLAST) program predicts energy consumption, energy system performance and cost for new or existing buildings.

BLAST contains three major sub-programs:

Space Load Prediction computes hourly space loads based on weather data and user inputs detailing the building construction and operation.

Air Distribution System Simulation uses the computed space loads, weather data, and user inputs.

Central Plant Simulation computes monthly and annual fuel and electrical power consumption.

Heat Balance Loads Calculator (HBLC) -- Graphical interface for producing BLAST input files.

WINLCCID 98 -- LCCID (Life Cycle Cost in Design) performs Life Cycle Cost Analyses.

Program Name and Description	Order Number	Price
PC BLAST Includes: BLAST, HBLC, BTEXT, WIFE, CHILLER, Report Writer, Report Writer File Generator, Comfort Report program, Weather File Reporting Program, Control Profile Macros for Lotus or Symphony, and the Design Week Program. The single CD-ROM includes s the BLAST Manual, technical articles and theses, nearly 400 processed weather files, browsing engine, source code.	3B486E3-0898	\$1500
PC BLAST Package Upgrade from level 295+	4B486E3-0898	\$450
WINLCCID 98: executable version for 386/486/Pentium	3LCC3-0898	\$295
WINLCCID 98: update from WINLCCID 97	4LCC3-0898	\$195

The last four digits of the catalog number indicate the month and year the item was released or published.

VisualDOE and LEED Training for 2006 Architectural Energy Corporation is pleased to announce three VisualDOE training sessions. In San Francisco on May 18-19, in Boulder, CO, on November 13-14 and sometime in July or August in New York. Each 2-day session focuses on DOE-2, the VisualDOE interface, VisualDOE 4 new features, general energy simulation skills, and LEED-NC 2.1 and 2.2 energy savings calculations for green buildings. To register or get more training information, please go to VisualDOE training page at <http://www.archenergy.com/products/visualdoe/training/>